

Automatic Tank Gauging/Monitoring Inspection Checklist

Facility:

Manufacturer:

Facility ID #:

Model:

Answer yes/no for each tank	Tank 1	Tank 2	Tank 3	Tank 4
Checked for presence of probe in tanks. 40 CFR 280.40(a)(2)				
Checked for presence of monitoring box and evidence that device is working 40 CFR 280.40(a)(2)				
Equipment is third party certified 40 CFR 280.40(a)(3)				
Documentation shows that water in bottom of tank is checked monthly to nearest one-eighth of an inch. 40 CFR 280.43(a)(6)				
Records of ATG equipment calibration (in accordance with manufactures instructions), maintenance and repair available. 40 CFR 280.45(c)				
Leak test records for last 12 months available. 40 CFR 280.40(a)(2)				

Comments:

LIST THE FOLLOWING:

1. RECORDS NOT AVAILABLE
2. RECORDS THAT INDICATE FAIL
3. RECORDS THAT INDICATE WARNING ALARMS
4. INDICATE VIOLATIONS

Inspector's Signature:

Date: